

The following samples were collected from JFK Library rooms:

- M23
- M04
- U02

# JFK Particle Counts 11/02/18

Date 11/02/18																	
Building	RM #			M23	Time	Building	RM #			M04	Time	Building	RM #			U02	Time
JFK	3 HEPAs running				11:27	JFK					11:01	JFK	2 HEPAs running				
	Sa1	Sa2	Sa3	AVE		Sa1	Sa2	Sa3	AVE		Sa1	Sa2	Sa3	AVE			
0.3	1732	1701	1839	1757.333	0.3	1781	1753	1791	1775	0.3	1222	1147	1334	1234.333			
0.5	402	451	407	420	0.5	289	288	329	302	0.5	185	228	245	219.3333			
1	178	212	234	208	1	82	88	151	107	1	52	101	90	81			
2.5	187	237	221	215	2.5	50	61	141	84	2.5	35	100	108	81			
5	60	67	40	55.66667	5	28	14	35	25.66667	5	7	28	24	19.66667			
10	24	17	13	18	10	20	20	35	25	10	4	21	11	12			
Temp	72.3					Temp	70.9					Temp	72.5				
RH	38.1					RH	40.3					RH	37.9				

Building	RM #			Time
JFK	Outside Air intake loading dock			11:57
	Sa1	Sa2	Sa3	AVE
0.3	10595	9312	11019	10308.67
0.5	939	917	1177	1011
1	302	325	366	331
2.5	208	247	260	238.3333
5	63	80	60	67.66667
10	15	17	25	19
Temp	58.2			
RH	53.6			

Building	RM #			Hall outside U02	Time
JFK					11:15
	Sa1	Sa2	Sa3	AVE	
0.3	2702	2693	2747	2714	
0.5	763	762	773	766	
1	414	423	401	412.6667	
2.5	424	417	433	424.6667	
5	119	122	111	117.3333	
10	39	57	54	50	
Temp	73.6				
RH	39.5				