

The following samples were collected from Williamson Hall rooms:

- 310
- 310B
- 310D
- 312

Williamson Hall Particle Counts 3/21/19

Building	WAL	RM #	310	Time	Building	WAL	RM #	310D	Time	Building	WAL	RM #	310B	Time
		310					310D					310B		
	Sa1	Sa2	Sa3			Sa1	Sa2	Sa3			Sa1	Sa2	Sa3	
0.3	13788	13622	13341	13584	0.3	13805	13435	13617	13619	0.3	14737	14639	14198	14525
0.5	657	633	654	648	0.5	789	702	740	744	0.5	793	733	786	771
1	102	72	66	80	1	217	158	138	171	1	178	131	162	157
2.5	132	68	54	85	2.5	316	240	185	247	2.5	224	227	159	203
5	44	19	8	24	5	126	90	49	88	5	84	91	56	77
10	19	6	8	11	10	41	20	23	28	10	43	21	11	25
Temp	74				Temp	74				Temp	75			
RH	25				RH	25				RH	25			

Building	WAL	RM #	312	Time	Building	WAL	RM #	Outside	Time	Building	WAL	RM #		Time
		312					Outside							
	Sa1	Sa2	Sa3			Sa1	Sa2	Sa3			Sa1	Sa2	Sa3	
0.3	15364	14789	15157	15103	0.3	48314	48918	49989	49074	0.3				
0.5	877	779	759	805	0.5	2725	2749	2784	2753	0.5				
1	143	150	135	143	1	371	349	337	352	1				
2.5	163	134	140	146	2.5	246	257	218	240	2.5				
5	53	45	30	43	5	59	59	43	54	5				
10	11	10	7	9	10	7	20	15	14	10				
Temp	75				Temp	65				Temp				
RH	24				RH	30				RH				